



**Legend**

**Residential Samples (763 Samples)**

**Michigan Part 201 Drinking Water Criteria**

- No Detections of PFNA, PFOA, PFHxA, PFOS, PFHxS, PFBS, or HFPO-DA (364)
- One or more of the 7 PFAS Detected Below Criteria (311)
- One or more of the 7 PFAS Detected Above Criteria (88)

**Other Groundwater Samples**

- Monitoring Well Samples

⊕ VAS Samples

▲ Previous VAS Samples

**Michigan Part 201 Drinking Water Criteria**

- No Detections of PFNA, PFOA, PFHxA, PFOS, PFHxS, PFBS, or HFPO-DA
- One or more of the 7 PFAS Detected Below Criteria
- One or more of the 7 PFAS Detected Above Criteria

Grayling Army Airfield Boundary

**GRAYLING AIRFIELD  
PFAS HEAT MAP**

**GRAYLING AREA PFAS  
CRAWFORD COUNTY, MICHIGAN**



Michigan Part 201 Residential & Nonresidential  
Drinking Water Criteria (DWC), ng/L  
 PFHxA = 400,000    PFHxS = 51  
 PFOA = 8            PFOS = 16  
 PFNA = 6            HFPO-DA = 370  
 PFBS = 420

Prepared: 5/6/2024

