



# GOBIERNO DE PUERTO RICO

Autoridad de Acueductos y Alcantarillados

November 22, 2017

The Coast Guard facilities, located in the Ramey Base of the Aguadilla Municipality, are supplied by the Aguadilla Urbano System, Aguadilla WTP PWSID 3293.

PRASA certifies that the water it receives is potable water. The results of the bacteriological sampling collected at the Aguadilla WTP on November 20, 2017 and analyzed on November 20, 2017, are included below:

- Residual chlorine- 2.22 mg / L
- Total chlorine- 2.90 mg / L
- pH- 7.15 SU
- Temperature- 27.5 ° C
- E. Coli Analyte - Negative
- Total coliform Analyte - Negative
- Parameter- Colilert
- Method- SM 9223

Ing. María I. Crespo Lorenzo, EIT

Compliance Manager  
West Region

22/NOV/2017



Autoridad de Acueductos  
y Alcantarillados

Centro Regional de Operaciones OESTE: Urbanización Sultana, Calle Tenerife número 10, Mayagüez, PR 00680